

CITY OF PHOENIX  
PHOENIX, OREGON  
ORDINANCE NO. 964

**AN ORDINANCE AMENDING CHAPTERS 2.3.5, AND 2.4.4, AND ADDING CHAPTER 3.12 TO THE PHOENIX LAND DEVELOPMENT CODE, ALSO KNOWN AS LDC14-11.**

**WHEREAS**, the City of Phoenix intends to protect the public health, safety, and welfare of persons and property within its jurisdiction; and

**WHEREAS**, the City of Phoenix wishes to protect its small town character and quality of life including, but not limited to the unobstructed enjoyment of the natural night sky; and

**WHEREAS**, the City wishes to reduce the spillage of light from one property onto adjacent properties and visual impairment caused by glare; and


**WHEREAS**, the City of Phoenix wishes to reduce the inefficient, wasteful, and unnecessary consumption of energy, the depletion of nonrenewable natural resources used to produce energy, and the resulting atmospheric pollution by gaseous emissions (most notably carbon dioxide, carbon monoxide, sulfur dioxide, and nitrous oxide).

**NOW THEREFORE**, the City of Phoenix **ORDAINS** as follows:

**Section 1.** The Land Development Code of the City of Phoenix is hereby amended as proposed in Exhibit A.

**Section 2. Effective Date:** This ordinance shall become effective 30 days after its adoption.

**PASSED AND ADOPTED** by the City Council and signed by me in authentication thereof on this 21<sup>st</sup> day of May, 2015

  
\_\_\_\_\_  
Mayor

ATTEST:

  
\_\_\_\_\_  
Recorder



Exhibit A  
PLDC as Amended by LDC 14-11  
Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

Chapter 2.3.5 is amended as follows:

**D. Open Space Design**

1. Common open spaces shall include at least two of the following improvements:
  - a. benches for seating;
  - b. public art such as a statue;
  - c. a water feature such as a fountain;
  - d. a children's play structure;
  - e. a gazebo;
  - f. picnic tables;
  - g. gardens;
  - h. an indoor or outdoor sports court for one or more of the following: tennis, basketball, volleyball, badminton, racquetball, and handball/paddleball
2. Residential developments that may house children shall provide at least one common open space with a children's play structure.
3. For security purposes, all common open spaces shall be adequately illuminated in accordance with Chapter 3.12 – Outdoor Lighting and ~~shielded during hours of darkness~~. Landscaping shall be designed and maintained to avoid security risks.

Chapter 2.4.4 is amended as follows:

**2.4.4 – Architectural Guidelines and Standards**

**A. Architectural Continuity and Quality.** New and remodeled buildings may have their own architectural style but there must be some architectural continuity with the other structures located within the area. All building designs located within the Commercial Highway District must be of a high architectural quality and shall incorporate the following:

1. Continuous building walls of greater than 50 feet shall be avoided. Breaks in the wall plane shall be incorporated into the building design.
2. Entrances to the buildings shall be clearly defined architecturally. Entrances shall include decorative pavement treatments in order to tie into the parking lot pedestrian circulation systems.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

3. Exterior building materials shall be of high quality and shall be selected based upon their weathering properties. Generally, materials such as stucco, brick, or masonry block should be used for exterior walls.
  4. When the building is part of a larger complex, continuity of materials and design shall be required.
- B. Lighting.** Project lighting shall be provided ~~for in order to create safe low-light conditions, security reasons. Fixture types shall be down mounted or shielded when located adjacent to residential development and in accordance with Chapter 3.12 – Outdoor Lighting.~~ in order to create safe low-light conditions.
- C. Roof-mounted equipment.** Roof-mounted mechanical equipment is not allowed unless completely screened within an equipment well or screened by a parapet wall.
- D. Detailing.** Architectural detailing shall be consistent on all elevations.
- E. Trash Enclosures.** Trash enclosures shall be constructed of 6-foot high masonry walls with solid metal gates. The floor of the enclosure shall be constructed of concrete with a 6-foot by 10-foot concrete apron placed in front of the enclosure. The masonry materials used shall be selected to match the materials used in the building or buildings that it serves. Trash enclosures shall not be located within 25 feet of a public entrance or a required pedestrian walkway.
- F. Parking lot lighting.** Parking lot lighting shall be provided for parking lots containing more than 10 spaces. ~~The light fixtures shall be designed to light the parking area using down-mounted, low-profile light fixtures.~~ Parking lots with more than 10 vehicle parking spaces shall also include low-profile pedestrian scale lighting of pedestrian walkways and bicycle parking areas. All outdoor lighting shall comply with Chapter 3.12
- G. Bicycle Parking.** Bicycle parking shall be integrated into the design for development within the C-H zone district. The location of the spaces must be coordinated with the location and orientation of vehicle parking, bicycle lanes, and pedestrian walkways. Enclosed bicycle parking shall be designed to be architecturally compatible with the design of the building or buildings located on the site. (See the Parking chapter of this development code for other bicycle parking requirements.)
- H. Pedestrian Circulation.** Projects that require more than 50 vehicle parking spaces shall also be required to provide the following separate pedestrian circulation improvements:
1. Covered walkways, a trellis structure planted with vines or other solution that is designed to provide pedestrians with shade and protection from the weather.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

2. All pedestrian circulation areas must be lighted with pedestrian scale light fixtures in compliance with Chapter 3.12.
3. Transit stops, on-site connections to transit stops, or designated passenger pick up areas shall be required if deemed appropriate by the Planning Department based upon the size of the project and input from the Rogue Valley Transit District (RVTD) or if requested by RVTD.
4. Driveway Improvements. Parking lots over three acres in size shall provide street improvements, including curbs, sidewalks, and street trees, in compliance with the local street standards in Table 3.5.2.

Chapter 2.4.5 is amended as follows:

**F. Vehicle, Truck, Boat, Motorcycle, or RV Sales.** These uses may be approved if it has been shown that the use incorporates the following:

1. Sales lots must include a minimum of a 20-foot landscape setback between the back of sidewalk and the edge of the vehicle parking, display area, or building.
2. No vehicle display will be allowed in the required landscape setback area.
3. Vehicle display areas shall not encroach upon the required customer and employee parking spaces.
4. ~~Outside project lighting must be designed to minimize light spillage onto adjacent properties.~~ Pole lighting must not be higher than 15 feet and must be shielded from the surrounding public streets and from I-5 and shall comply with Chapter 3.12 – Outdoor Lighting.
5. All repair and detailing activities must be conducted within an enclosed building.

**G. Self-Storage Facilities.** These uses may be approved if it has been shown that the following design requirements have been provided:

1. Architectural Standards:
  - a. Exterior materials used in the construction of the storage units shall be concrete masonry block with a decorative finish such as split-faced or fluted block.
  - b. Long exterior walls shall be broken up with masonry pilasters or insets or pop outs in the wall plane at a minimum of 30 feet on center.
  - c. The roof material may be metal but it shall have a non-glaring finish.
  - d. The roof eaves shall be finished and shall incorporate rain gutters and down spouts.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

- e. Security fencing shall be provided. The fencing shall be decorative wrought iron or other decorative metal. Chain link fencing is not permitted.
2. Site Development Standards:
- a. The following minimum building setbacks shall apply:
    - i. Front: 20 feet
    - ii. Side and rear: 0, except when adjacent to another street frontage in which case the minimum would be 15 feet or in the case where the development would be adjacent to a residential land use, in which case the minimum setback would be 5 feet.
  - b. Landscaping: A dense landscape screen must be included on all elevations that abut a street frontage or abut residential land uses. The landscape treatment must include a combination of trees, shrubs, and ground cover. The area must be served by an automatic underground irrigation system. All landscaping shall meet the requirements of Chapter 3.3 – Landscaping, Street Trees, Fences, and Walls.
  - c. Project Lighting: All project lighting shall ~~be designed not to spill onto adjacent properties~~ comply with Chapter 3.12 – Outdoor Lighting.

Chapter 2.5.9 is amended as follows:

- E. Outdoor Lighting.** ~~Building-mounted Outdoor lighting and aerial-mounted floodlighting shall be shielded from above in such a manner that the bottom edge of the shield shall be below the light source. Ground-mounted floodlighting or light projection above the horizontal plane is prohibited between midnight and sunrise. All lighting shall be shielded so that the direct illumination shall be confined to the property boundaries of the light source~~ shall comply with Chapter 3.12 – Outdoor Lighting.

Chapter 2.6.9 is amended as follows:

- E. Outdoor Lighting.** ~~Building-mounted Outdoor lighting and aerial-mounted floodlighting shall be shielded from above in such a manner that the bottom edge of the shield shall be below the light source. Ground-mounted floodlighting or light projection above the horizontal plane is prohibited between midnight and sunrise. All lighting shall be shielded so that the direct illumination shall be confined to the property boundaries of the light source~~ shall comply with Chapter 3.12 – Outdoor Lighting.



## Exhibit A

PLDC as Amended by LDC 14-11  
Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

Chapter 3 is amended by adding Section 3.12 – *Outdoor Lighting*, as follows:

### Chapter 3.12 – Outdoor Lighting

#### Sections

- 3.12.1 – Purpose
- 3.12.2 – Definitions
- 3.12.3 – Lighting area classifications
- 3.12.4 – Applicability
- 3.12.5 – Exemptions
- 3.12.6 – Standards for non-residential lighting
- 3.12.7 – Standards for residential lighting.

#### 3.12.1 – Purpose

The purpose of this Ordinance is to provide regulations for outdoor lighting that will: permit the use of outdoor lighting that does not exceed the maximum levels specified in IES recommended practices for night-time safety, utility, security, productivity, enjoyment, and commerce; minimize adverse offsite impacts of lighting such as light trespass, and obtrusive light; curtail light pollution, reduce skyglow and improve the nighttime environment for astronomy; protect the natural environment from the adverse effects of night lighting from gas or electric sources; and conserve energy and resources to the greatest extent possible.

#### 3.12.2 – Definitions

- A. Absolute Photometry. Photometric measurements (usually of a solid-state luminaire) that directly measures the footprint of the luminaire. Reference Standard IES LM-79.
- B. Architectural Lighting. Lighting designed to reveal architectural beauty, shape and/or form for which lighting for any other purpose is incidental.
- C. Authority. The adopting municipality, agency or other governing body.
- D. Astronomic Time Switch. An automatic lighting control device that switches outdoor lighting relative to time of solar day with time of year correction.
- E. Backlight. For an exterior luminaire, lumens emitted in the quarter sphere below horizontal and in the opposite direction of the intended orientation of the luminaire. For luminaires with symmetric distribution, backlight will be the same as front light.
- F. BUG. A luminaire classification system that classifies Backlight (B), Uplight (U), and Glare (G).



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

- G. **Canopy.** A covered, unconditioned structure with at least one side open for pedestrian and/or vehicular access. (An unconditioned structure is one that may be open to the elements and has no heat or air conditioning.)
- H. **Common Outdoor Areas.** One or more of the following: a parking lot; a parking structure or covered vehicular entrance; a common entrance or public space shared by all occupants of a site; parks, plazas, and similar outdoor gathering and recreational areas.
- I. **Curfew.** A time defined by the authority when outdoor lighting is reduced or extinguished.
- J. **Cutoff or 100% Cutoff.** See definition for “Fully Shielded Luminaire” in this Section.
- K. **Emergency Conditions.** Generally, lighting that is only energized during an emergency; lighting fed from a backup power source; or lighting for illuminating the path of egress solely during a fire or other emergency situation; or lighting for security purposes used solely during an alarm.
- L. **Footcandle.** The unit of measure expressing the quantity of light received on a surface. One footcandle is the illuminance produced by a candle on a one foot square surface from a distance of one foot.
- M. **Forward Light.** For an exterior luminaire, lumens emitted in the quarter sphere below horizontal and in the direction of the intended orientation of the luminaire.
- N. **Fully Shielded Luminaire.** A luminaire constructed and installed in such a manner that all light emitted by the luminaire, either directly from the lamp or a diffusing element, or indirectly by reflection or refraction from any part of the luminaire, is projected below the horizontal plane through the luminaire’s lowest light-emitting part.
- O. **Glare.** Lighting entering the eye directly from luminaires or indirectly from reflective surfaces that causes visual discomfort or reduced visibility.
- P. **Hardscape.** Stone, brick, concrete, asphalt or other similar finished surfaces intended primarily for walking, such as sidewalks and pathways.
- Q. **Hardscape Area.** The area measured in square feet of all hardscape. It is used to calculate the Total Site Lumen Limit in both the Prescriptive and Performance Method I methods. See Chapter 1.3 of the PLDC for a definition of hardscape.
- R. **Hardscape Perimeter.** The perimeter measured in linear feet is used to calculate the Total Site Lumen Limit in the Performance Method. See Chapter 1.3 of the PLDC for a definition of hardscape.
- S. **IDA.** International Dark-Sky Association.
- T. **IESNA.** Illuminating Engineering Society of North America.
- U. **Industry Standard Lighting Software.** Lighting software that calculates point-by-point illuminance that includes reflected light using either ray-tracing or radiosity methods.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,

deletions are ~~stricken~~;

all other text appears as it will in the final,  
amended document.

- V. Lamp. A generic term for a source of optical radiation (i.e. "light"), often called a "bulb" or "tube". Examples include incandescent, fluorescent, high-intensity discharge (HID), low pressure sodium (LPS), light-emitting diode (LED), metal halide (MH), and induction.
- W. Landscape Lighting. Lighting of trees, shrubs, or other plant material as well as ponds and other landscape features.
- X. LED. Lighting Emitting Diode.
- Y. Light Pollution. Any adverse effect of artificial light including, but not limited to, glare, light trespass, skyglow, energy waste, compromised safety and security, and impacts on the nocturnal environment.
- Z. Light Trespass. Light that falls beyond the property it is intended to illuminate.
- AA. Lighting. "Electric" or "man-made" or "artificial" lighting. See "lighting equipment".
- BB. Lighting Equipment. Equipment specifically intended to provide gas or electric illumination, including but not limited to, lamp(s), luminaire(s), ballast(s), poles, posts, lens(s), and related structures, electrical wiring, and other necessary or auxiliary components.
- CC. Lighting Zone. An overlay zoning system establishing legal limits for lighting for particular parcels, areas, or districts in a community.
- DD. Low Voltage Landscape Lighting. Landscape lighting powered at less than 15 volts and limited to luminaires having a rated initial luminaire lumen output of 525 lumens or less.
- EE. Lumen. The unit of measure used to quantify the amount of light produced by a lamp or emitted from a luminaire (as distinct from "watt," a measure of power consumption).
- FF. Luminaire. The complete lighting unit (fixture), consisting of a lamp, or lamps and ballast(s) (when applicable), together with the parts designed to distribute the light (reflector, lens, diffuser), to position and protect the lamps, and to connect the lamps to the power supply.
- GG. Luminaire Lumens. For luminaires with relative photometry per IES, it is calculated as the sum of the initial lamp lumens for all lamps within an individual luminaire, multiplied by the luminaire efficiency. If the efficiency is not known for a residential luminaire, assume 70%. For luminaires with absolute photometry per IES LM-79, it is the total luminaire lumens. The lumen rating of a luminaire assumes the lamp or luminaire is new and has not depreciated in light output.
- HH. Lux. A unit of illuminance. One lux is one lumen per square meter. 1 Lux is a unit of incident illuminance approximately equal to 1/10 footcandle.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

- II. Mounting Height. The height of the photometric center of a luminaire above grade level.
- JJ. New lighting. Lighting for areas not previously illuminated; newly installed lighting of any type except for replacement lighting or lighting repairs.
- KK. Ornamental lighting. Lighting that does not impact the function and safety of an area but is purely decorative, or used to illuminate architecture and/or landscaping, and installed for aesthetic effect.
- LL. Ornamental Street Lighting. A luminaire intended for illuminating streets that serves a decorative function in addition to providing optics that effectively deliver street lighting. It has a historical period appearance or decorative appearance, and has the following design characteristics:
- designed to mount on a pole using an arm, pendant, or vertical tenon;
  - opaque or translucent top and/or sides;
  - an optical aperture that is either open
  - or enclosed with a flat, sag or drop lens;
  - mounted in a fixed position; and
  - with its photometric output measured using Type C photometry per IESNA LM-75-01.
- MM. Outdoor Lighting. Lighting equipment installed within the property line and outside the building envelopes, whether attached to poles, building structures, the earth, or any other location; and any associated lighting control equipment.
- NN. Partly Shielded Luminaire. A luminaire with opaque top and translucent or perforated sides, designed to emit most light downward.
- OO. Photoelectric Switch. A control device employing a photocell or photodiode to detect daylight and automatically switch lights off when sufficient daylight is available.
- PP. Relative photometry. Photometric measurements made of the lamp plus luminaire, and adjusted to allow for light loss due to reflection or absorption within the luminaire. Reference standard: IES LM-63.
- QQ. Repair(s). The reconstruction or renewal of any part of an existing luminaire for the purpose of its ongoing operation, other than relamping or replacement of components including capacitor, ballast or photocell. Note that retrofitting a luminaire with new lamp and/or ballast technology is not considered a repair and for the purposes of this ordinance the luminaire shall be treated as if new.



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

- “Repair” does not include normal relamping or replacement of components including capacitor, ballast or photocell.
- RR. Replacement Lighting. Lighting installed specifically to replace existing lighting that is sufficiently broken to be beyond repair.
  - SS. Sales Area (Outdoor). Uncovered area used for sales of retail goods and materials, including but not limited to automobiles, boats, tractors and other farm equipment, building supplies, and gardening and nursery products.
  - TT. Seasonal lighting. Temporary lighting installed and operated in connection with holidays or traditions.
  - UU. Shielded Directional Luminaire. A luminaire that includes an adjustable mounting device allowing aiming in any direction and contains a shield, louver, or baffle to reduce direct view of the lamp.
  - VV. Sky Glow. The brightening of the nighttime sky that results from scattering and reflection of artificial light by moisture and dust particles in the atmosphere. Skyglow is caused by light directed or reflected upwards or sideways and reduces one's ability to view the night sky.
  - WW. Temporary lighting. Lighting installed and operated for periods not to exceed 60 days, completely removed and not operated again for at least 30 days.
  - XX. Time Switch. An automatic lighting control device that switches lights according to time of day.
  - YY. Translucent. Allowing light to pass through, diffusing it so that objects beyond cannot be seen clearly (not transparent or clear).
  - ZZ. Unshielded Luminaire. A luminaire capable of emitting light in any direction including downwards.
  - AAA. Uplight. For an exterior luminaire, flux radiated in the hemisphere at or above the horizontal plane.
  - BBB. Vertical Illuminance. Illuminance measured or calculated in a plane perpendicular to the site boundary or property line.

**3.12.3 – Lighting area classifications**

Different types of land uses, activities, and operations require different levels of ambient lighting. Lighting zones are hereby determined according to the land use district in which a particular property is located. Table 3.12.3 defines lighting area classifications by land use district map designation and describes each lighting zone in terms of its purpose and suitability for certain types and intensities of outdoor lighting.

|          |     |     |     |    |     |    |    |     |
|----------|-----|-----|-----|----|-----|----|----|-----|
| Greenway | R-1 | R-2 | R-3 | CC | C-H | GI | LI | PUD |
|----------|-----|-----|-----|----|-----|----|----|-----|



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

|      |      |      |      |      |      |      |      |        |
|------|------|------|------|------|------|------|------|--------|
| LZ-1 | LZ-1 | LZ-1 | LZ-2 | LZ-2 | LZ-3 | LZ-3 | LZ-3 | Varies |
|------|------|------|------|------|------|------|------|--------|

Table 3.12.3 Lighting Area Classifications.

**3.12.4 – Applicability**

Except as described below, all outdoor lighting installed after the date of effect of this section shall comply with these requirements. This includes, but is not limited to, new lighting, replacement lighting, or any other lighting whether attached to structures, poles, the earth, or any other location, including lighting installed by any third party. Where the provisions of this chapter conflict with other sections of the Land Development Code or other municipal codes, the more restrictive regulation shall control.

**3.12.5 – Exemptions**

The following types of lighting applications and operational procedures are explicitly exempt from the requirements of this chapter.

- A. Lighting within public right-of-way or easement for the principal purpose of illuminating streets or roads. No exemption shall apply to any lighting within the public right of way or easement when the purpose of the luminaire is to illuminate areas outside the public right of way or easement, unless regulated with a streetlighting ordinance;
- B. Lighting for public monuments and statuary;
- C. Lighting solely for signs (lighting for signs is regulated by the Sign Ordinance);
- D. Repairs to existing luminaires not exceeding 25% of total installed luminaires;
- E. Temporary lighting for theatrical, television, performance areas and construction sites lasting fewer than 3 days;
- F. Underwater lighting in swimming pools and other water features;
- G. Temporary lighting and seasonal lighting provided that individual lamps are less than 10 watts and 70 lumens;
- H. Lighting that is only used under emergency conditions;
- I. In lighting zones 2, 3 and 4, low voltage landscape lighting controlled by an automatic device that is set to turn the lights off at one hour after the site is closed to the public or at a time established by the City;
- J. Lighting specified or identified in a specific use permit;
- K. Lighting required by federal or state laws and regulations.

**3.12.6 – Standards for non-residential lighting**

- A. Prescriptive Method. An outdoor lighting installation complies with this section if it meets the requirements of subsections 1, 2, 3 below.

Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

1. Total Site Lumen Limit. The total installed initial luminaire lumens of all outdoor lighting shall not exceed the total site lumen limit. The total site lumen limit shall be determined using either the Parking Space Method (Table A) or the Hardscape Area Method (Table B and B-2). Only one method shall be used per permit application, and for sites with existing lighting, existing lighting shall be included in the calculation of total installed lumens. The total installed initial luminaire lumens is calculated as the sum of the initial luminaire lumens for all luminaires.
2. Limits of offsite impacts. All luminaires shall be rated and installed according to Table C.
3. Full or 100% cutoff lighting. All lighting shall be full cutoff and shall not emit light above 90 degrees.
4. Exceptions. Ornamental parking lighting shall be permitted by special permit only, and shall meet the requirements of Table D-1 for Backlight, Table D-2 for Uplight, and Table D-3 for Glare, without the need for external field-added modifications.

B. Performance Method I. An outdoor lighting installation complies with this section if it meets the requirements of subsections 1 and 2 below.

1. Total Site Lumen Limit. The total installed initial luminaire lumens of all lighting systems on the site shall not exceed the allowed total initial site lumens. The allowed total initial site lumens shall be determined using Tables D and E. For sites with existing lighting, existing lighting shall be included in the calculation of total installed lumens. The total installed initial luminaire lumens is calculated as the sum of the initial luminaire lumens for all luminaires.
2. Limits to Off Site Impacts. All luminaires shall be rated and installed using either





Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

Option A or Option B. Only one option may be used per permit application.

- a. Option A: All luminaires shall be rated and installed according to Table C.
- b. Option B: The entire outdoor lighting design shall be analyzed using industry standard lighting software including interreflections in the following manner:
  - i. Input data shall describe the lighting system including luminaire locations, mounting heights, aiming directions, and employing photometric data tested in accordance with IES guidelines. Buildings or other physical objects on the site within three object heights of the property line must be included in the calculations.
  - ii. Analysis shall utilize an enclosure comprised of calculation planes with zero reflectance values around the perimeter of the site. The top of the enclosure shall be no less than 33 feet (10 meters) above the tallest luminaire. Calculations shall include total lumens upon the inside surfaces of the box top and vertical sides and maximum vertical illuminance (footcandles and/or lux) on the sides of the enclosure.
  - iii. The proposed design complies if the total lumens on the inside surfaces of the virtual enclosure are less than 15% of the total site lumen limit; and the maximum vertical illuminance on any vertical surface is less than the allowed maximum illuminance per Table F.

C. Performance Method II. Sites under 1 acre that are within the LZ-2 and LZ-3 lighting area classes may demonstrate compliance with this Chapter by meeting the following requirements:

- 1. Full or 100% cutoff lighting. All lighting shall be full cutoff and shall not emit light above 90 degrees.
- 2. Photometric plan required. A photometric plan shall be submitted for review that accurately depicts the locations and types of lighting measures and illuminance in footcandles or lumens at final grade throughout the entire site and ten (10) feet beyond the perimeter of the site.
- 3. Maximum and minimum luminance. Illumination levels shall comply with those listed in the following Table 3.12.6.C:

| Area/Activity Type          | Min. Illuminance (FC) | Max. Illuminance (FC) |
|-----------------------------|-----------------------|-----------------------|
| Building entrances/Exits    | 5                     | 10                    |
| Parking Areas               | 1                     | 5                     |
| Parking Structure           | 5                     | 10                    |
| Other Outdoor Areas         | 1                     | 5                     |
| Loading Areas and Platforms | 10                    | 15                    |
| Under canopies              | 5                     | 15                    |



Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

|                           |    |    |
|---------------------------|----|----|
| Heavy Equipment Operation | 10 | 25 |
|---------------------------|----|----|

Table 3.12.6 Illumination Levels.

4. Maximum illuminance at property line. Maximum illuminance at any point in the vertical plane of the property line shall be less than 0.2 foot-candles.

**3.12.7 – Standards for residential lighting.**

A. General Requirements. For residential properties including multiple family residential properties not having common areas, all outdoor luminaires shall be fully shielded, 100% cutoff and shall not exceed the allowed lumen output in Table G, row 2.

B. Exceptions.

1. One partly shielded or unshielded luminaire at the main entry, not exceeding the allowed lumen output in Table G row 2.
2. Any other partly shielded or unshielded luminaires not exceeding the allowed lumen output in Table G row 3.
3. Low voltage landscape lighting aimed away from adjacent properties and not exceeding the allowed lumen output in Table G row 4.
4. Shielded directional flood lighting aimed so that direct glare is not visible from adjacent properties and public and private streets and pedestrian ways and not exceeding the allowed lumen output in Table G row 5.
5. Open flame gas lamps.
6. Lighting installed with a vacancy sensor, where the sensor extinguishes the lights no more than 15 minutes after the area is vacated, provided that the luminaire is shielded, 100% cutoff.
7. Lighting exempt per Section III (B.).

C. Requirements for Residential Landscape Lighting.

1. Shall comply with Table G.
2. Shall not be aimed onto adjacent properties.

**3.12.8 – Lighting by special permit**

A. *High Intensity and Special Purpose Lighting.* The following lighting systems are prohibited from being installed or used except by special use permit:

1. Temporary lighting in which any single luminaire exceeds 20,000 initial luminaire lumens or the total lighting load exceeds 160,000 lumens.
2. Aerial Lasers.



Exhibit A  
PLDC as Amended by LDC 14-11  
Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

3. Searchlights.
  4. Other very intense lighting defined as having a light source exceeding 200,000 initial luminaire lumens or an intensity in any direction of more than 2,000,000 candelas.
  5. Focused light emitted by remotely operated aerial devices (drones). Warning and identification lights as required by state and federal laws and regulations for such devices are not subject to this requirement.
- B. Upon special permit issued by the Department, lighting not complying with the technical requirements of this ordinance but consistent with its intent may be installed for complex sites or uses or special uses including, but not limited to, the following applications:
1. Sports facilities, including but not limited to unconditioned rinks, open courts, fields, and stadiums.
  2. Construction lighting.
  3. Lighting for industrial sites having special requirements, such as petrochemical manufacturing or storage, shipping piers, etc.
  4. Parking structures.
  5. Urban parks
  6. Ornamental and architectural lighting of bridges, public monuments, statuary and public buildings.
  7. Theme and amusement parks.
  8. Correctional facilities.
- C. Standards for approval of special permit for lighting
1. Has sustained every reasonable effort to mitigate the effects of light on the environment and surrounding properties, supported by a signed statement describing the mitigation measures. Such statement shall be accompanied by the calculations required for the Performance Method.
  2. Employs lighting controls to reduce lighting at a Project Specific Curfew ("Curfew") time to be established in the Permit.
  3. Complies with the Performance Method after Curfew.
  4. The Authority shall review each such application. A permit may be granted if, upon review, the Authority believes that the proposed lighting will not create unwarranted glare, sky glow, or light trespass.



## Exhibit A

PLDC as Amended by LDC 14-11

Additions to existing text are underlined,  
deletions are ~~stricken~~;  
all other text appears as it will in the final,  
amended document.

**3.12.8 – Existing Lighting.** Lighting installed prior to the effective date of this ordinance shall comply with the following standards.

- A. Amortization. On or before January 1, 2029, all outdoor lighting shall comply with this Code.
- B. New Uses or Structures, or Change of Use. Whenever there is a new use of a property (zoning or variance change) or the use or occupancy category as defined by the applicable building code is changed, all outdoor lighting on the property shall be brought into compliance with this Ordinance before the new or changed use or occupancy commences.
- C. Additions or Alterations
  1. Major additions. If a major addition occurs on a property, lighting for the entire property shall comply with the requirements of this Code. For purposes of this section, the following are considered to be major additions:
    - a. Additions of 25 percent or more in terms of additional dwelling units, gross floor area, seating capacity, or parking spaces, either with a single addition or with cumulative additions after the effective date of this Ordinance.
    - b. Single or cumulative additions, modification or replacement of 25 percent or more of installed outdoor lighting luminaires existing as of the effective date of this Ordinance.
  2. Minor modifications, additions, or new lighting fixtures for non-residential and multifamily dwellings. For non-residential and multifamily dwellings, all additions, modifications, or replacement of more than 25 percent of outdoor lighting fixtures existing as of the effective date of this Ordinance shall require the submission of a complete inventory and site plan detailing all existing and any proposed new outdoor lighting. Any new lighting shall meet the requirements of this Ordinance.
  3. Resumption of Use after Abandonment. If a property with non-conforming lighting is not occupied for a period of six months or more, then all outdoor lighting shall be brought into compliance with this Ordinance before any further use of the property occurs.

### **3.12.8 – Violations and Enforcement.**

Outdoor lighting installed or maintained in violation of any provision of this section, or other applicable provisions of the Phoenix Land Development Code (PLDC), shall be subject to the provisions of Chapter 1.4 – Enforcement of the PLDC.

### **3.12.9 Tables**



**Exhibit A**  
**PLDC as Amended by LDC 14-11**  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

**Table A - Allowed Total Initial Luminaire Lumens per Site for Nonresidential Outdoor Lighting, Per Parking Space Method.** May only be applied to properties up to 10 parking spaces (including handicapped accessible spaces).

| LZ-0      | LZ-1      | LZ-2      | LZ-3      | LZ-4      |
|-----------|-----------|-----------|-----------|-----------|
| 350       | 490       | 630       | 840       | 1,050     |
| lms/space | lms/space | lms/space | lms/space | lms/space |

**Table B - Allowed Total Initial Lumens for Nonresidential Sites, per Outdoor Lighting, Hardscape Area Method.** May be used for any project. When lighting intersections of site drives and public streets or road, a total of 600 square feet for each intersection may be added to the actual site hardscape area to provide for intersection lighting.

| LZ-0                                 | LZ-1                                  | LZ-2                                 | LZ-3                                 | LZ-4                                 |
|--------------------------------------|---------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|
| Base Allowance                       |                                       |                                      |                                      |                                      |
| 0.5 lumens<br>per SF of<br>hardscape | 1.25 lumens<br>per SF of<br>Hardscape | 2.5 lumens<br>per SF of<br>hardscape | 5.0 lumens<br>per SF of<br>hardscape | 7.5 lumens<br>per SF of<br>hardscape |

**Table B-2 - Lumen Allowances for, in Addition to Base Allowance**

|   | LZ-0 | LZ-1   | LZ-2   | LZ-3  | LZ-4  |
|---|------|--|--|---|---|
| Additional allowances for sales and service facilities.<br>No more than two additional allowances per site, Use it or Lose it.  |      |  |  |   |   |
| <b>Outdoor Sales Lots.</b> This allowance is lumens per square foot of uncovered sales lots used exclusively for the display of vehicles or other merchandise for sale, and may not include driveways, parking or other non-sales areas. To use this allowance, luminaires must be within 2 mounting heights of sales lot area.   | 0    | 4<br>lumens<br>per<br>square<br>foot of<br>hardscape | 8<br>lumens<br>per<br>square<br>foot of<br>hardscape | 16<br>lumens<br>per<br>square<br>foot of<br>hardscape | 16<br>lumens<br>per<br>square<br>foot of<br>hardscape |
| <b>Outdoor Sales Frontage.</b> This allowance is for lineal feet of sales frontage immediately adjacent to the principal viewing location(s) and unobstructed for its viewing length. A corner sales lot may include two adjacent sides provided that a different principal viewing location exists for each side. In order to use this allowance, luminaires must be located between the principal viewing | 0    | 0  | 1,000<br>per<br>LF                                   | 1,500<br>per<br>LF                                    | 2,000<br>per<br>LF                                    |



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

|   |   |   |  |   |   |
|---|---|---|--|---|---|
| location and the frontage outdoor sales area.   |   |   |  |   |   |
| <b>Drive Up Windows.</b> In order to use this allowance, luminaires must be within 20 feet horizontal distance of the center of the window. | 0 | 2,000 lumens per drive-up window            | 4,000 lumens per drive-up window             | 8,000 lumens per drive-up window              | 8,000 lumens per drive-up window              |
| <b>Vehicle Service Station.</b> This allowance is lumens per installed fuel pump.   | 0 | 4,000 lumens per pump (based on 5 fc horiz) | 8,000 lumens per pump (based on 10 fc horiz) | 16,000 lumens per pump (based on 20 fc horiz) | 24,000 lumens per pump (based on 20 fc horiz) |

**Table C - Maximum Allowable Backlight, Uplight and Glare (BUG) Ratings.** May be used for any project. A luminaire may be used if it is rated for the lighting zone of the site or lower in number for all ratings B, U and G. Luminaires equipped with adjustable mounting devices permitting alteration of luminaire aiming in the field shall not be permitted.

|   | LZ-0 | LZ-1 | LZ-2 | LZ-3 | LZ-4 |
|---|------|------|------|------|------|
| Allowed Backlight Rating*   |      |      |      |      |      |
| Greater than 2 mounting heights from property line                          | B1   | B3   | B4   | B5   | B5   |
| 1 to less than 2 mounting heights from property line and ideally oriented** | B1   | B2   | B3   | B4   | B4   |
| 0.5 to 1 mounting heights from property line and ideally oriented**         | B0   | B1   | B2   | B3   | B3   |
| Less than 0.5 mounting height to property line and properly oriented**      | B0   | B0   | B0   | B1   | B2   |

\*For property lines that abut public walkways, bikeways, plazas, and parking lots, the property line may be considered to be 5 feet beyond the actual property line for purpose of determining compliance with this section. For property lines that abut public roadways and public transit corridors, the property line may be considered to be the centerline of the public roadway or public transit corridor for the purpose of determining compliance with this section. NOTE: This adjustment is relative to Table C-1 and C-3 only and shall not be used to increase the lighting area of the site.

\*\* To be considered 'ideally oriented', the luminaire must be mounted with the backlight portion of the light output oriented perpendicular and towards the property line of concern.

**Table C - 2 Maximum Allowable Uplight (BUG) Ratings - Continued**

| Table C-2   | LZ-0 | LZ-1 | LZ-2 | LZ-3 | LZ-4 |
|---|------|------|------|------|------|
| Allowed Uplight Rating  | U0   | U1   | U2   | U3   | U4   |
| <b>Allowed % light emission above 90° for street or Area lighting</b> | 0%   | 0%   | 0%   | 0%   | 0%   |

**Table C - 3 Maximum Allowable Glare (BUG) Ratings – Continued**



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

| Table C-3  | LZ-0 | LZ-1 | LZ-2 | LZ-3 | LZ-4 |
|--|------|------|------|------|------|
| Allowed Glare Rating   | G0   | G1   | G2   | G3   | G4   |
| Any luminaire not ideally oriented*** with 1 to less than 2 mounting heights to any property line of concern | G0   | G0   | G1   | G1   | G2   |
| Any luminaire not ideally oriented*** with 0.5 to 1 mounting heights to any property line of concern         | G0   | G0   | G0   | G1   | G1   |
| Any luminaire not ideally oriented*** with less than 0.5 mounting heights to any property line of concern    | G0   | G0   | G0   | G0   | G1   |

\*\*\* Any luminaire that cannot be mounted with its backlight perpendicular to any property line within 2X the mounting heights of the luminaire location shall meet the reduced Allowed Glare Rating in Table C-3.

**Table D Performance Method Allowed Total Initial Site Lumens** *May be used on any project.*

| Lighting Zone                | LZ-0 | LZ-1 | LZ-2 | LZ-3  | LZ-4  |
|------------------------------|------|------|------|-------|-------|
| Allowed Lumens Per SF        | 0.5  | 1.25 | 2.5  | 5     | 7.5   |
| Allowed Base Lumens Per Site | 0    | 3500 | 7000 | 14000 | 21000 |

**Table E Performance Method Additional Initial Luminaire Lumen Allowances.** All of the following are "use it or lose it" allowances. All area and distance measurements in plan view unless otherwise noted.

| Lighting Application   | LZ-0 | LZ-1 | LZ-2  | LZ-3  | LZ-4  |
|--|------|------|-------|-------|-------|
| <b>Additional Lumens Allowances for All Buildings except service stations and outdoor sales facilities. A MAXIMUM OF THREE (3) ALLOWANCES ARE PERMITTED. THESE ALLOWANCES ARE "USE IT OR LOSE IT".</b>                     |      |      |       |       |       |
| <b>Building Entrances or Exits.</b> This allowance is per door. In order to use this allowance, luminaires must be within 20 feet of the door.   | 400  | 1000 | 2000  | 4000  | 6000  |
| <b>Building Facades.</b> This allowance is lumens per unit area of building façade that are illuminated. To use this allowance, luminaires must be aimed at the façade and capable of illuminating it without obstruction. | 0    | 0    | 8/SF  | 16/SF | 24/SF |
| <b>Sales or Non-sales Canopies.</b> This allowance is lumens per unit area for the total area within the drip line of the canopy. In order to qualify for this allowance, luminaires must be located under the canopy.     | 0    | 3/SF | 6/SF  | 12/SF | 18/SF |
| <b>Guard Stations.</b> This allowance is lumens per unit area of guardhouse plus 2000 sf per vehicle lane. In  | 0    | 6/SF | 12/SF | 24/SF | 36/SF |



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

|   |   |                                  |                                  |                                  |                                  |
|---|---|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| order to use this allowance, luminaires must be within 2 mounting heights of a vehicle lane or the guardhouse.  |   |                                  |                                  |                                  |                                  |
| <b>Outdoor Dining.</b> This allowance is lumens per unit area for the total illuminated hardscape of outdoor dining. In order to use this allowance, luminaires must be within 2 mounting heights of the hardscape area of outdoor dining   | 0 | 1/SF                             | 5/SF                             | 10/SF                            | 15/SF                            |
| <b>Drive Up Windows.</b> This allowance is lumens per window. In order to use this allowance, luminaires must be within 20 feet of the center of the window.  | 0 | 2,000 lumens per drive-up window | 4,000 lumens per drive-up window | 8,000 lumens per drive-up window | 8,000 lumens per drive-up window |
| Additional Lumens Allowances for Service Stations only.<br>Service stations may not use any other additional allowances.  |   |                                  |                                  |                                  |                                  |
| <b>Vehicle Service Station Hardscape.</b> This allowance is lumens per unit area for the total illuminated hardscape area less area of buildings, area under canopies, area off property, or areas obstructed by signs or structures. In order to use this allowance, luminaires must be illuminating the hardscape area and must not be within a building, below a canopy, beyond property lines, or obstructed by a sign or other structure.            | 0 | 4/SF                             | 8/SF                             | 16/SF                            | 24/SF                            |
| <b>Additional Lumens Allowances for Outdoor Sales facilities only.</b><br>Outdoor Sales facilities may not use any other additional allowances.<br><b>NOTICE:</b> lighting permitted by these allowances shall employ controls extinguishing this lighting after a curfew time to be determined by the Authority.   |   |                                  |                                  |                                  |                                  |
| <b>Outdoor Sales Lots.</b> This allowance is lumens per square foot of uncovered sales lots used exclusively for the display of vehicles or other merchandise for sale, and may not include driveways, parking or other non sales areas and shall not exceed 25% of the total hardscape area. To use this allowance, Luminaires must be within 2 mounting heights of the sales lot area.  | 0 | 4/SF                             | 8/SF                             | 12/SF                            | 18/SF                            |
| <b>Outdoor Sales Frontage.</b> This allowance is for lineal feet of sales frontage immediately adjacent to the principal viewing location(s) and unobstructed for its viewing length. A corner sales lot may include two adjacent sides provided that a different principal viewing location exists for each side. In order to use this allowance, luminaires must be located between the principal viewing location and the frontage outdoor sales area. | 0 | 0                                | 1,000/LF                         | 1,500/LF                         | 2,000/LF                         |

**Table E - Performance Method Additional Initial Lumen Allowances (cont.)**



Exhibit A  
 PLDC as Amended by LDC 14-11  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

| Lighting Application  | LZ-0 | LZ-1 | LZ-2    | LZ-3    | LZ-4    |
|---|------|------|---------|---------|---------|
| <b>Vehicle Service Station Canopies.</b> This allowance is lumens per unit area for the total area within the drip line of the canopy. In order to use this allowance, luminaires must be located under the canopy.   | 0    | 8/SF | 16/SF   | 32/SF   | 32/SF   |
| <b>Additional Lumens Allowances for Outdoor Sales facilities only.</b><br>Outdoor Sales facilities may not use any other additional allowances.<br><b>NOTICE:</b> lighting permitted by these allowances shall employ controls extinguishing this lighting after a curfew time to be determined by the Authority.   |      |      |         |         |         |
| <b>Outdoor Sales Lots.</b> This allowance is lumens per square foot of uncovered sales lots used exclusively for the display of vehicles or other merchandise for sale, and may not include driveways, parking or other non sales areas and shall not exceed 25% of the total hardscape area. To use this allowance, Luminaires must be within 2 mounting heights of the sales lot area.  | 0    | 3/SF | 6/SF    | 12/SF   | 18/SF   |
| <b>Outdoor Sales Frontage.</b> This allowance is for lineal feet of sales frontage immediately adjacent to the principal viewing location(s) and unobstructed for its viewing length. A corner sales lot may include two adjacent sides provided that a different principal viewing location exists for each side. In order to use this allowance, luminaires must be located between the principal viewing location and the frontage outdoor sales area. | 0    | 0    | 1000/LF | 1500/LF | 2000/LF |

**Table F Maximum Vertical Illuminance at any point in the plane of the property line**

| LZ-0                  | LZ-1                 | LZ-2                 | LZ-3                 | LZ-4                  |
|-----------------------|----------------------|----------------------|----------------------|-----------------------|
| 0.05 FC or<br>0.5 LUX | 0.1 FC or<br>1.0 LUX | 0.3 FC or<br>3.0 LUX | 0.8 FC or<br>8.0 LUX | 1.5 FC or<br>15.0 LUX |

**Table G - Residential Lighting Limits**

| Lighting Application   | LZ-0          | LZ-1      | LZ-2      | LZ-3      | LZ-4      |
|--|---------------|-----------|-----------|-----------|-----------|
| <b>Row 1</b> Maximum Allowed Luminaire Lumens* for Unshielded Luminaires at one entry only | Not permitted | 420 lms   | 630 lms   | 630 lms   | 630 lms   |
| <b>Row 2</b> Maximum Allowed Luminaire Lumens* for each Fully Shielded Luminaire           | 630 lms       | 1,260 lms | 1,260 lms | 1,260 lms | 1,260 lms |
| <b>Row 3</b> Maximum Allowed Luminaire Lumens* for each                                    | Not permitted | 315 lms   | 315 lms   | 315 lms   | 315 lms   |



**Exhibit A**  
**PLDC as Amended by LDC 14-11**  
 Additions to existing text are underlined,  
 deletions are ~~stricken~~;  
 all other text appears as it will in the final,  
 amended document.

|   |               |                               |           |           |           |
|---|---------------|-------------------------------|-----------|-----------|-----------|
| Unshielded Luminaire excluding main entry   |               |                               |           |           |           |
| <b>Row 4</b> Maximum Allowed Luminaire Lumens* for each Landscape Lighting                  | Not permitted | Not permitted                 | 1,050 lms | 2,100 lms | 2,100 lms |
| <b>Row 5</b> Maximum Allowed Luminaire Lumens* for each Shielded Directional Flood Lighting | Not permitted | 1,260 lms                     | 1,260 lms | 2,100 lms | 2,100 lms |
| <b>Row 6</b> Maximum Allowed Luminaire Lumens* for each Low Voltage Landscape Lighting      | Not permitted | 30 lms, max. of 10 luminaires | 525 lms   | 525 lms   | 525 lms   |

\* Luminaire lumens equals Initial Lamp Lumens for a lamp multiplied by the number of lamps in the luminaire.